

**Response to Queries/Clarifications
from Design Engineer
to the Sydney Tar Ponds Agency**

4) Are the maintenance flows to be handled by electric or diesel driven pumps?

Response: Contractor preference, but proposed type is to be stated.

5) Is the "Area for Pumping Equipment" as shown on drawings of fixed area and location?

Response: No. If more a larger footprint is necessary or locations area may need to be moved closer to intake structure is this possible? Yes, provided access is not impaired.

Does this query/clarification warrant an Addenda? _____ Yes No.

If "Yes", please generate an Addendum Notification using STPA Form F 60800 and put your response on that form.

If "No", state reasons why.

Signature: _____

Date: _____

 